

**MUNICIPAL DISTRICT OF ADARE-RATHKEALE**  
**MEETING TO BE HELD ON MONDAY 11<sup>TH</sup> MARCH, 2024**

**Question submitted by Councillor K. Sheahan**

I will ask at the next meeting for an update on the boil water notice for the residents of Askeaton and surrounding area.

**REPLY:**

Uisce Éireann upgrade works to lift Boil Water Notice for customers supplied by Foynes/Shannon Estuary Public Water Supply are nearing completion.

Our teams have successfully carried out the necessary shutdowns at the plant to facilitate the installation and operation of the suction pipework.

Pre-commissioning is continuing with the Commissioning Engineer this week to establish the required setpoints for the ultraviolet disinfection unit and associated equipment.

We are now working with our contractors on the required shutdown controls on the existing water treatment plant to ensure that non-compliant water does not enter the clear water tank.

Following this there will be commissioning and collection of sampling data for the HSE to review and Uisce Éireann will consult with the HSE to discuss if the Boil Water Notice can be lifted.

We are grateful to the elected representatives and members of the public who continue to share our updates.

**Ciara McCaughley,  
Uisce Éireann.**

**8<sup>th</sup> March, 2024**